

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES
SAMPLE COLLECTED ON 12/01/2024 BY M. Samad Khan & RECEIVED IN THE LABORATORY ON 12/01/2024

PARTICULARS OF THE SAMPLE					PARAMETERS EXAMINED (VALUE IN MG/L except pH, Otherwise Mentioned)														
Sl. NO	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1	Ram Nagar	Naga Parclayat	Harnagar (Bidaspur-Harnagar Road)	Sauhardh International School	1.0	7.3	378	150	158	36	12	23	15	0.2	0.0	0.3	252	NT	Neg
Min. Max Permissible Limit (IS:10500/2012)					1.5 NTU	6.5-8.5		200-600	200-600	75-200	30-100	250-1000	200-400	1.0-4.0 NR	45 NR	1-1.5	500-2000	0.01-0.05 NR	VE
Remarks- Analyzed parameters of above samples is within permissible limit.																			

Aditya Kumar Gupta
Principal

Sauhardh International School
Reg. No.-203101420221221152234
UDise Code-10011212011
Harnagar-845103

Rajeev Kumar
Manager

Sauhardh International School
Reg. No.-203101420221221152234
UDise Code-10011212011
Harnagar-845103

Anil Kumar
SICHEMIST
DLWTL
P.H. Division, Bettiah